



# CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Certificate No.: CE250301009819

**Product**

Low Voltage DC Control Cabinet

**Applicant**

ZHEJIANG TENGGEN ELECTRIC CO.,LTD.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang  
Province, P.R.China

**Type/Model**

TG-HKG-D

**Technical data**

Ue:DC1500V;Ui:1500V;InA(Main Busbar):2500A;  
Icw(Main Busbar):50kA/1s; Ipk(Main Busbar): 105kA;Time  
constant T: 4ms;IP42;50Hz;Indoor

This is to certify that, on the basis of the tests undertaken as per Report No.  
02402-24119C20387, the submitted sample(s) of the above item complies with:

**EN IEC 61439-2:2021**

and fulfills testing requirements of the European Directive:

**2014/35/EU**

This report is to verify the compliance of the sample submitted by the manufacturer only,  
and does not include the manufacturing process. Users shall affix the mark in accordance  
with the related legislation.

**Valid from: Sep.22,2025**

**Valid until: Sep.21,2028**

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNATURE:

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE