

# CERTIFICATE

## of Conformity

### Low Voltage Directive (EU) 2014/35

**Registration No.:** AN 50695256 0001  
**Report No.:** CN25MAK0 001  
**Holder:** Zhejiang Tengen Electric Co., Ltd.  
Sulv Industrial Area,  
Liushi Town, Yueqing City,  
325604 Zhejiang  
P.R. China  
**Product:** AC contactor

#### Type designation listed on the next page

This certificate of conformity is based on an evaluation of a sample of the above-mentioned product. Technical Report and documentation are at the License Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive (EU) 2014/35, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

**Date:** 2025-11-03

#### Certification Body

*Yang Yongming*

Yongming Yang



**TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg**

The CE marking may be used if all relevant and effective EC Directives/Regulations are complied with.

# CERTIFICATE

## of Conformity

### Low Voltage Directive (EU) 2014/35

**Registration No.:** AN 50695256 0001

**Product:** AC contactor

**Identification:**

**Type Designation**

CJX2F-115, CJX2F-115N, CJX2F-1154, CJX2F-1154N,  
TeC5-115, TeC5-115N, TeC5-1154, TeC5-1154N,  
CJX2F-150, CJX2F-150N, CJX2F-1504, CJX2F-1504N,  
TeC5-150, TeC5-150N, TeC5-1504, TeC5-1504N,  
CJX2F-320C, CJX2F-3204C

Serial number : Engineering samples

**Technical Data:**

Ue : 380V/660V/690V/1000V AC  
Uimp : 12kV; Ui : 1000V  
Ith : 200A(CJX2F-115/115N/1154/1154N,  
TeC5-115/115N/1154/1154N)  
250A(CJX2F-150/150N/1504/1504N,  
TeC5-150/150N/1504/1504N)  
320A(CJX2F-320C/3204C)  
Iq : 50kA(380V); Poles : 3P/4P

**Utilization category:**

**AC-3:**

Model: CJX2F-115/1154, TeC5-115/1154  
CJX2F-150/1504, TeC5-150/1504

Ue : 380V/660V/690V/1000V AC

Ie : 115A/86A/86A/46A(CJX2F-115/1154, TeC5-115/1154)  
150A/108A/108A/50A(CJX2F-150/1504, TeC5-150/1504)

**AC-4:**

Model: CJX2F-115N/1154N, TeC5-115N/1154N  
CJX2F-150N/1504N, TeC5-150N/1504N

Ue : 380V/690V AC

Ie : 52A/49A(CJX2F-115N/1154N, TeC5-115N/1154N)  
60A/57A(CJX2F-150N/1504N, TeC5-150N/1504N)

**AC-1:**

Model: CJX2F-320C, CJX2F-3204C

Ue : 690V AC

Ie : 320A



**TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg**

The CE marking may be used if all relevant and effective EC Directives/Regulations are complied with.

# CERTIFICATE

## of Conformity

### Low Voltage Directive (EU) 2014/35

#### Identification:

#### Type Designation

CJX 2 F - x y z  
(1) (2) (3) (4) (5) (6)

#### Possible values:

- (1):Enterprise feature code: CJX means contactor
- (2):Design serial number code: 2 means 2 version
- (3):Class group code: F means series designation
- (4):Ie current under AC-3 utilization category  
code:115=115A, 150=150A, 320=320A
- (5):y=blank means 3 poles type,  
y=4 means 4 poles type
- (6):y=blank means normal type,  
y=C means AC-1 utilization category contactor,  
y=N means Reversing contactor,  
y=Z means DC-operated contactor

TeC 5 - x y z  
(1) (2) (3) (4) (5) (6)

#### Possible values:

- (1):Enterprise feature code: TeC means contactor
- (2):Design serial number code: 5 means 5 version
- (3):blank
- (4):Ie current under AC-3 utilization category  
code:115=115A, 150=150A
- (5):y=blank means 3 poles type,  
y=4 means 4 poles type
- (6):y=blank means normal type,  
y=N means Reversing contactor,  
y=Z means DC-operated contactor



**TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg**

The CE marking may be used if all relevant and effective EC Directives/Regulations are complied with.